



NOTES:

EACH INSPECTION PORT / CLEANOUT SHALL INCLUDE THE FOLLOWING:

1. FOR AN UNDERGROUND FLUSH MOUNTED OBSERVATION WELL / CLEANOUT PROVIDE A TUBE MADE OF NON-CORROSIVE MATERIAL, SCHEDULE 40 P.V.C. OR EQUAL, AT LEAST 3 FEET LONG WITH AN INSIDE DIAMETER OF 6 INCHES. PERFORATED PIPE IS REQUIRED FOR ALL INSPECTION PORTS OR CLEANOUTS USED AS INSPECTION PORTS.
2. THE TUBE SHALL HAVE A FACTORY ATTACHED BRASS OR HIGH IMPACT PLASTIC HEAD WITH RIBS TO PREVENT ROTATION WHEN REMOVING LOCKABLE CAP.
3. LOCKABLE CAP SHALL BE BRASS AND RATED FOR HS-20 LOADING IN VEHICULAR AREAS, MOUNTED FLUSH TO GRADE. LOCKABLE CAP MAY BE HIGH IMPACT PLASTIC THAT IS UV STABLE IN NON-VEHICULAR LOADING AREA, AT LEAST 6 INCHES ABOVE GRADE.
4. CONCRETE APRONS AROUND CLEANOUTS ARE OPTIONAL.

MODIFICATIONS OF DRAWINGS ARE ONLY PERMITTED BY WRITTEN AUTHORIZATION FROM EAGLE BAY

DATE: 05-01-15

DWG: 12 OF 14